



NOTES:

1. ROCK LINING TO BE INSTALLED TO FORM A STABLE STRUCTURE WITH A MINIMUM OF VOIDS, AND EACH PLACED IN CONTACT WITH ADJACENT ROCKS.
2. ROCK LINING SHALL BE SOUND, DENSE, AND DURABLE ANGULAR ROCK WITH A MINIMUM SPECIFIC GRAVITY OF 2.6.
3. ROCK LINED CHANNELS LARGER THAN THE DIMENSIONS SHOWN, OR ON SLOPES STEEPER THAN 5% SHALL BE DESIGNED BY A CIVIL ENGINEER.
4. IF A GRAVEL FILTER LAYER IS SUBSTITUTED FOR FILTER FABRIC, MATERIAL SHALL BE A MIXTURE OF CLEAN, WASHED SAND AND GRAVEL, COMPRISED OF MATERIAL LESS THAN 1 1/2" DIA. IN SIZE.
5. CHECK DAMS MAY BE INSTALLED IN ROCK LINED SWALE DEPENDING UPON APPLICATION AND SITE CONDITIONS. SEE BMP-310.

Rock Lined Swale



THE TAHOE REGIONAL PLANNING AGENCY (TRPA) SHALL NOT BE RESPONSIBLE FOR THE ACCURACY OR COMPLETENESS OF ELECTRONIC COPIES OF THIS DETAIL.